



⚠ T874N1024/Q674F1261




T874R1129/Q674L1181




1F58-45



BLOWER COIL
24V TERMINALS



OUTDOOR UNIT
24V TERMINAL



BLUE

BROWN

BLUE

YELLOW

YELLOW

HEATPUMP W/15 TO 30KW BLOWER COIL



SET ADJUST HEAT ANTICIPATOR (SEE BLOWER COIL INSTRUCTIONS).



WHEN OUTDOOR THERMOSTAT (USED AS COMPRESSOR CUTOFF) IS INSTALLED, REMOVE JUMPER Y-Y1.



IF OUTDOOR THERMOSTAT IS USED TO STAGE HEAT, REMOVE JUMPER W3-O1 AND DH-O1.

FACTORY
WIRING

FIELD
WIRING

LOW VOLTAGE
HIGH VOLTAGE

