

WARNING
USE COPPER CONDUCTORS
ONLY SUITABLE FOR AT LEAST
75° C.

DANGER
ELECTRICAL SHOCK HAZARD
DISCONNECT POWER BEFORE
SERVICING.

	Factory	Field	Optional
High Voltage			
Low Voltage			

Composite Wiring Diagram QH Series 3 460-60-3, Represents Max. KW Electric Heat

- ▲▲▲▲ Labeled wires connect if no options used.
- ▲ Install jumper for hi speed blower oper. on models 36, 42, 48, and 60.
- ▲ Remove jumper when Low Amb. Bypass is installed.
- ▲ Remove jumper when CS2000A Energy Monitor is installed.

Optional CS2000A Energy Monitor (Use With "A" Thermostat Only)

